



OFFICE OF INSURANCE AND SAFETY FIRE COMMISSIONER

JOHN W. OXENDINE
COMMISSIONER OF INSURANCE
SAFETY FIRE COMMISSIONER
INDUSTRIAL LOAN
COMMISSIONER
COMPTROLLER GENERAL

Seventh Floor, West Tower
2 Martin Luther King Jr. Dr.
Atlanta, Georgia 30334
(404) 656-2056 or (404) 656-4031
www.gainsurance.org

Re: Portable Containment Berm

This to advise you that the use of a portable containment berm has been approved for use for fuel deliveries to an aboveground storage tank subject to the following requirements:

1. Portable containment berms are approved for aboveground tanks with a maximum storage of 2,000 gallons.
2. Local personnel must be present at the delivery site to set up the containment berm prior to the arrival of the delivery tanker. This individual must remain at the site during the actual fuel delivery process by the tanker driver. The berm can be removed and stored after the tanker has completed its delivery and exits the property.
3. The owner of the aboveground storage tank must include these exact procedures in their SPCC (Spill Prevention, Control and Countermeasure) Plan or be listed in the facilities' operational manual indicating who is responsible.
4. Portable containment berm specifications must be included in the plan review package.
5. The request for portable berms must be completed and returned to this office with plans and site approvals.

Be reminded that the berm must be set up the proper distance from the aboveground storage tank for each delivery (fifteen feet for diesel, twenty-five feet for gasoline).

The portable containment berm, and procedures listed above, meets all the requirements of Georgia code 120-3-11.07.

Please feel free to contact this office at 404 656-9798 with any questions.

Contractor/Engineer _____ Date _____

Facility Manager/Owner _____ Date _____